

Model ZW222

Two Way Altitude Level Control Valve

Application

The Zurn Wilkins Model ZW222 Two Way Altitude Level Control Valve accurately controls the high water level in a storage tank or reservoir without the need for floats or sensors. The valve features on/off service and is installed on the fill line to close drip tight once the high water level is reached. The water level is measured by a field installed remote sensing line installed from the reservoir to the pilot control valve. This valve is used where water supply and distribution is through the same line.

Standards Compliance:

- ANSI/AWWA C530
- Meets the requirements of NSF/ANSI 61*
- *(0.25% MAX. WEIGHTED AVERAGE LEAD CONTENT)

Materials

Main Valve Body Ductile Iron ASTM A536 Main Valve Bonnet Ductile Iron ASTM A536

Disc Guide Stainless Steel Seat Stainless Steel Disc Buna-N Rubber

Nylon Reinforced Buna-N Diaphragm

Stainless Steel Stem Stainless Steel Spring

FDA Approved Fusion Epoxy Coating

Adjustment Range

The pilot adjustment range can be selected between 5' and 230'

Standard Features

Globe Style Body

Blue Epoxy Coated, FDA Approved

Pilot Assembly

- SXL "Wye" Type Strainer
- Accelerator Pilot Control
- 850XL Isolation Valves

Closing Speed Control

ANSI Class 150 Flanges

Position Indicator

Pressure Gauges

Gauge Isolation and Sensing Line Flush Valve

Stainless Steel Braided Hoses/ Brass Fittings

Water 33°F to 140°F Temperature Rating:

300 psi max. Pilot Rating:

BODY C	ONFIGURATIONS	GLOBE ST	ANGLE				
END CONNECTION	PRESSURE RATING	FULL PORT	REDUCED PORT	STYLE BODY			
Threaded	400 psi max.	1 1/4"-3"	n/a	1 1/4"-3"			
Flanged	ANSI Class 150, 250 psi max.	1 1/2"-16"	3"-10"	1 1/2"-10"			
	ANSI Class 300, 400 psi max.	1 1/2 -10	3 -10	1 1/2 -10			
Grooved	Grooved 300 psi max.		n/a	1 1/2"-10"			
MINIMUM INLET PRESSURE 10 PSI							







Options (Add suffix letters to ZW222)

Function

Delayed drawdown level before valve reopens D

Ε Solenoid override to shut-off valve

Η With Pressure Sustaining

С Hydraulic Check with Isolation Valve

0 Opening Speed Control (Standard on 4" or

smaller)

Body

Angle Style Body Α

R Reduced Port Body

Connections

IPS Grooved G ΤH NPT Threaded

Υ ANSI Class 300 Flanges

Pilot System

5'-55' adjustment range L1 L2 45'-85' adjustment range 75'-230' adjustment range L3

Stainless Steel Tubing & Fittings ST F Atmospheric "wet" drain

RV Pilot Installed on reverse side

Schematic Diagram

Description of Standard Features Item

Main Valve 1

2 850XL Isolation Valve

3 SXL "Wye" Type Strainer

4 Pressure Gauge


PV-ACL-3A Accelerator Pilot 5

6 PV-ALT Altitude Control Pilot

7 **ZPI Position Indicator**

8 3-Way Gauge Isolation/Sensing Line Flush Valve

40XL2 Single Check Lead Free q



Zurn Industries, LLC | Wilkins

1747 Commerce Way, Paso Robles, CA U.S.A. 93446 Ph. 855-663-9876, Fax 805-238-5766 In Canada | Zurn Industries Limited

3544 Nashua Drive, Mississauga, Ontario L4V 1L2 Ph. 905-405-8272, Fax 905-405-1292


Date: 9/16 Document No. ACV-ZW222 Product No. Model ZW222

Globe and Angle Main Valve Dimensions

DIM	FULL PORT		VALVE SIZE INCHES (mm)													
DIIVI	FOLL FORT	1 1/4 (32)	1 1/2(38)	2 (50)	2 1/2 (65)	3 (80)	4 (100)	6 (150)	8 (200)	10 (250)	12 (300)	14 (350)	16 (400)			
	Threaded	7 1/4	7 1/4	9 7/16	11	12 1/2										
A	Class 150 Flange		8 1/2	9 3/8	11	12	15	20	25 3/8	29 3/4	34	39	41 3/8			
^	Class 300 Flange		9	10	11 5/8	13 1/4	15 5/8	21	26 7/16	31 1/8	35 1/2	40 1/2	43 1/2			
	Grooved		8 1/2	9	11	12 1/2	15	20	25 3/8	29 3/4						
В	Diameter	5 5/8	5 5/8	6 3/4	8	9 3/16	11 11/16	15 3/4	20 1/8	23 11/16	27 1/2	31 3/4	34 1/2			
С	Max.	5 3/4	5 3/4	6 3/16	7 3/8	8	10 3/16	12 5/16	15 9/16	17 5/8	20 3/16	22 13/16	25 7/8			
	Threaded/Grooved	1 3/8	1 3/8	1 3/4	2 1/8	2 9/16	3 7/16	5	5	5 13/16	6 3/4	8 7/8	8 13/16			
D	Class 150 Flange		2 1/2	3	3 1/2	3 3/4	4 1/2	5 1/2	6 3/4	8	9 1/2	10 1/2	11 3/4			
	Class 300 Flange		3	3 1/4	3 3/4	4 1/8	5	6 1/4	7 1/2	8 3/4	10 1/4	11 1/2	12 3/4			
Е	NPT Body Tap	3/8	3/8	3/8	1/2	1/2	3/4	3/4	1	1	1	1	1			
F	NPT Cvr. Plug Tap	1/2	1/2	1/2	1/2	1/2	3/4	3/4	1	1	1	1	1			
G	NPT Cover Tap	3/8	3/8	3/8	1/2	1/2	3/4	3/4	1	1	1	1	1			
	Threaded	3 1/4	3 1/4	4 3/4	5 1/2	6 1/4										
н	Class 150 Flange		4	4 3/4	5 1/2	6	7 1/2	10	12 11/16	14 7/8						
"	Class 300 Flange		4 1/4	5	6	6 7/16	8	10 1/2	13 1/4	15 9/16						
	Grooved		4 7/16	4 3/4	5 1/2	6	7 1/2	10	12 11/16	14 7/8						
	Threaded	1 15/16	1 15/16	3 1/4	4	4 1/2										
,	Class 150 Flange		4	3 1/4	4	4	5	6	8	8 5/8						
J	Class 300 Flange		4 1/4	3 1/2	4 5/16	4 7/16	5 5/16	6 1/2	8 1/2	95/16						
	Grooved		3 3/16	3 1/4	4	4 1/4	5	6	8	8 5/8						
Valv	e Stem Internal Thread	10-32	10-32	10-32	10-32	1/4-20	1/4-20	1/4-20	3/8-16	3/8-16	3/8-16	3/8/16	3/8-16			
	Stem Travel (in)	7/16	7/16	3/4	7/8	1	1 3/16	1 3/4	2 3/8	2 13/16	3 7/16	3 13/16	4 5/16			
	Approx. Wt. (lbs)	22	26	36	55	70	130	240	440	720	820	1200	1550			


Reduced Port Main Valve Dimensions

DIM		VALVE SIZE INCHES (mm)									
DIIVI		3" (80)	4" (100)	6" (150)	8" (200)	10" (250)					
A	Class 150 Flange	10 1/4	14	17 3/4	21 7/16	26					
_ ^	Class 300 Flange	11	14 1/2	18 11/16	22 7/16	27 7/16					
В	Dia	6 3/4	9 3/16	11 11/16	15 3/4	20 1/8					
С	Max	6 3/8	8 7/16	12 5/16	13 1/4	16 3/4					
D	Class 150 Flange	3 3/4	4 1/2	5 1/2	6 3/4	8					
ן ט	Class 300 Flange	4 1/8	5	6 1/4	7 1/2	8 3/4					
Е	NPT Body Tap	3/8	1/2	3/4	3/4	1					
F	NPT Cvr. Plug Tap	3/8	1/2	3/4	3/4	1					
G	NPT Cvr. Tap	3/8	1/2	3/4	3/4	1					
Valve Stem Internal Thread		10-32	1/4-20	1/4-20	3/8-16	3/8-16					
S	Stem Travel (in)	3/4	1	1 1/5	1 3/4	2 3/8					
Approx	c. Wt. (Lbs) Class 150	50	90	160	280	480					



Globe Style Body


Angle Style Body




Reduced Port Body

Pilot System Dimensions

PILOT SYS		VALVE SIZE INCHES (mm)											
	DIM	1-1/4 (32)	1-1/2 (40)	2" (50)	2-1/2" (65)	3" (80)	4" (100)	6" (150)	8" (200)	10" (250)	12" (300)	14" (350)	16" (400)
	Χ	15 3/4	15 3/4	16	16 3/4	17	18 1/2	19 1/2	21	23 1/4	26 1/2	28 1/4	31 1/2
Full Port Body	Υ	4 1/4	4 1/4	5 1/4	6 1/2	6 9/16	7 3/4	9 9/16	11 3/4	13 1/4	15 1/8	17 1/4	18 5/8
Body	Z	11	11	11	10 3/4	11 1/2	12 3/4	14 1/2	17	18 3/4	19 1/4	21 1/4	23 1/2
Reduced	Χ					16 3/4	17	18 1/2	19 1/2	21			
Port	Υ					4 3/8	5 1/16	6 1/4	8 1/16	10 1/4			
Body	Z					10 3/4	11 1/2	12 3/4	14 1/2	17			
	Χ	15 1/2	15 1/2	16	16 1/4	17	18 1/4	19 1/2	21	22 3/4			
Angle Body	Υ	7 1/2	7 1/2	7 1/4	7 3/4	7 1/2	7 1/4	8 1/16	10 1/4	11 7/8			
Воду	Z	12	12	12 1/4	11 3/4	12	12 1/2	14 1/2	16 1/2	18 3/4			



Globe Pilot System Dimensions



Angle Pilot System Dimensions

Zurn Industries, LLC | Wilkins 1747 Commerce Way, Paso Robles, CA U.S.A. 93446 Ph. 855-663-9876, Fax 805-238-5766

In Canada | Zurn Industries Limited

3544 Nashua Drive, Mississauga, Ontario L4V 1L2 Ph. 905-405-8272, Fax 905-405-1292

Operation


The Zurn Wilkins Two Way Altitude Valve Model ZW222, has a pilot that senses the water level in the reservoir through a field installed pressure sensing line. This pressure opens and close the main altitude pilot. When the reservoir is at low water level, the altitude pilot pressurizes the cover of the accelerator pilot. The accelerator pilot vents the cover of the main valve downstream. The main valve opens to allow water to fill the reservoir. When the reservoir reaches the high water level, the altitude pilot vents the cover of the accelerator pilot. This allows the inlet water supply to refill the cover of the main valve, closing the valve drip tight. The high water level is adjusted by screwing the altitude pilot adjustment bolt in (clockwise) to increase the water level set point and unscrewing the adjustment bolt out (counterclockwise) to decrease the set point. The closing speed control valve can be screwed in (clockwise) to slow the main valve closing. An opening speed control is optional. The position indicator shows the main valve position. There is a bleed cock on the top of the position indicator to vent air from the main valve cover and indicator. The gauge isolation valve allows for the pressure gauge to be isolated when not in use to extend its life. To flush the reservoir sensing line of any air or debris, sensing line isolation valves are provided these valves also allow setting and verification of the set point and valve function.

Flow Characteristics

Valve Size	inches	1 1/4	1 1/2	2	2 1/2	3	4	6	8	10	12	14	16
	mm	32	40	50	65	80	100	150	200	250	300	350	400
Suggested	Max. Continuous	93	125	210	300	460	800	1800	3100	4900	7000	8400	11000
Flow (GPM)	Max Intermittent	120	160	260	375	600	1000	2250	4000	6150	8700	10500	13800
Suggested	Max. Continuous	6	8	13	19	29	50	113	195	309	550	665	870
Flow (Liters/sec)	Max. Intermittent	7.6	10	16.4	23	37	62	142	246	388	440	530	95


Note: Supply adequate flow restriction downstream of the ACV to keep the flow rates below maximum recommended values to prevent premature damage to the ACV. Suggested flow calculations are based on flow through Schedule 40 Pipe. Maximum Continuous flow is approx. 20 ft./sec (6.1 meters/sec) & Maximum Intermittent is approx. 25 ft./sec (7.6 meters/sec).

Typical Installation



www.zurn.com Page 3 of 4

BODY MINIMUM FRICTION LOSS



Specifications

The Two Way Altitude Level Control Valve shall be a single seated, line pressure operated, diaphragm actuated, globe or angle valve. The valve shall seal by means of a corrosion-resistant seat and resilient, rectangular seat disc. These and other parts shall be replaceable in the field; all such service and adjustments will be possible without removing the valve from the line. The main valve body shall be ductile iron ASTM A 536. The stem of the basic valve shall be guided top and bottom. The basic valve and its pilot control system shall contain no packing glands or stuffing boxes. The diaphragm shall not be used as a seating surface nor shall pistons be used as an operating medium. All internal and external ferrous surfaces shall be coated with a high quality, FDA Approved fusion epoxy coating. The valve shall be certified to NSF/ANSI Standard 61. The Two-Way Altitude Level Control Valve shall be a ZURN WILKINS Model ZW222.

Job Name ————————————————————————————————————	— Contractor	
Intellegentary	Positione	
Job Location ————————————————————————————————————	— Engineer	

www.zurn.com Page 4 of 4